

# Miller Drilling Co.

Contractors License No. 324634

## PUMP TEST REPORT

WELL OWNER: RANDY REID  
BILLING ADDRESS: 5955 WHISPERING OAK WAY  
PASO ROBLES, CA  
93446

Job# 19099  
Pump Set: N/A Well #: 5"  
Pump Size: 1 HP Well Depth: N/A  
Testing Method: EXISTING PUMP  
Perf Rec: N/A  
APN: \_\_\_\_\_

Standing Level Before Test: 194.36

LOCATION: 5955 WHISPERING OAK WAY

### TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:27	START	CLEAR NO ODOR		7.5
8:30	204	CLEAR NO ODOR		7.2
8:35	204.91	CLEAR NO ODOR		7.2
8:40	205.43	CLEAR NO ODOR		7.2
9:20	206.92	CLEAR NO ODOR		7.2
12:20	208.76	CLEAR NO ODOR		7.2
12:27	208.76	CLEAR NO ODOR		7.2

Notes: METER STOP: 41705.3                   7.01 GPM AVG  
METER START: 41537.1                   POSSIBLE LEAK IN NIPPLE UNDER WELL SEAL  
VOLUME PUMPED RELATED HORSEPOWER AT EXISTING WELL PUMP

STANDING LEVEL AFTER TEST: 176.11 AFTER 10 MIN  
FINAL TEST RESULTS:   Produced: 7.2 GPM for 4 hours on: 2/27/2014  
Test Run By:                   CHRIS - MARC

**DUPLICATE**  
Driller's Copy

STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
WATER WELL DRILLERS REPORT

Do not fill  
No. 207315


Notice of Intent No. 228460  
Local Permit No. or Date 87-267

State Well No. \_\_\_\_\_  
Other Well No. \_\_\_\_\_

(1) OWNER: Name L. P. King Land Co.  
Address 4080 Vineyard Dr.  
City Paso Robles, CA Zip 93446  
(2) LOCATION OF WELL (See Instructions):  
County San Luis Obispo Owner's Well Number \_\_\_\_\_  
Well address if different from above Whispering Oak Way  
Township 26 S Range 13 E Section 8  
Distance from cities, roads, railroads, fences, etc.  
off Jardine Rd.

(12) WELL LOG: Total depth 350 ft. Depth of completed well 344  
from ft. to ft. Formation (Describe by color, character, size or material)

0	-	3	Top Soil
3	-	14	Shaley Sand & Gravel
14	-	19	Sandy Brown Clay
19	-	52	Shaley Sand & Gravel
52	-	58	Brown Clay
58	-	67	Shaley Sand & Gravel
67	-	86	Greenish-Blue Clay
86	-	118	Blue Clay
118	-	122	Shaley Sand & Gravel
122	-	144	Brown Clay
144	-	150	Shaley Sand & Gravel
150	-	172	Shaley String & Greenish Blue Clay
172	-	186	Blue Clay
186	-	193	Shaley Sand & Gravel
193	-	221	Greenish-Brown Clay
221	-	227	Shaley Sand & Gravel
227	-	263	Greenish-Brown Clay
263	-	271	Shaley Sand & Gravel
271	-	279	Greenish-Brown Clay
279	-	298	Brown Clay
298	-	306	Shaley Sand & Gravel
306	-	324	Brown Clay
324	-	338	Shaley Sand & Gravel
338	-	344	Brown Clay



(3) TYPE OF WORK:  
New Well  Deepening   
Reconstruction   
Reconditioning   
Horizontal Well   
Destruction  (Describe destruction materials and procedures in Item 12)  
(4) PROPOSED USE:  
Domestic   
Irrigation   
Industrial   
Test Well   
Stock   
Municipal   
Other

(5) EQUIPMENT:  
Rotary  Reverse   
Cable  Air   
Other  Bucket

(6) GRAVEL PACK:  
Yes  No  Size Birdseye  
Diameter of bore 8-3/4"  
Pack from 23 to 344

(7) CASING INSTALLED:  
Steel  Plastic  Concrete

(8) PERFORATIONS:  
Type of perforation or size of screen

From ft.	To ft.	Dia. in.	Casing or Wall	From ft.	To ft.	Slot size
0	344	5"	CL160	344	284	3/16" drilled
						16 rows
						3 1/2" centers

(9) WELL SEAL:  
Was surface sanitary seal provided? Yes  No  If yes, to depth Aqua ft.  
Were struts sealed against pollution? Yes  No  Interval \_\_\_\_\_ ft.  
Method of sealing cement

(10) WATER LEVELS:  
Depth of first water, if known 186 ft.  
Standing level after well completion 180 ft.

(11) WELL TESTS:  
Was well test made? Yes  No  If yes, by whom? Aqua  
Type of test Pump  Baller  Air lift   
Depth to water at start of test 180 ft. At end of test 180 ft.  
Discharge 25 gal/min after 1 hours Water temperature \_\_\_\_\_  
Chemical analysis made? Yes  No  If yes, by whom? \_\_\_\_\_  
Was electric log made? Yes  No  If yes, attach copy to this report

If cap of this well is removed by anyone other than Aqua Engineering, Awalt & Sons, or persons authorized by Aqua Engineering, all structural warranties are null and void.

Work started 8-17 19 87 Completed 8-19 19 87  
WELL DRILLER'S STATEMENT:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
SIGNED A. Roy Awalt (Well Driller)  
NAME Aqua Engineering (Person, firm, or corporation) (Typed or printed)  
Address P.O. Box 398  
City San Miguel, CA Zip 93451  
License No. 348058 Date of this report 8-28-87

# Abalone Coast Analytical, Inc.

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401

Phone: 595-1080 Fax: 595-1080

ELAP #2661

Order #: 14-1408

Date/Time Rec'd: 3/11/14 1328

**Miller Drilling Company**

**301 North Main Street**

**Templeton, CA 93465**

**Contact: Kurt Bollinger**

**Phone: 434-1888**

Project: Reid

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	5955 Whispering	3/11/14	Total Coliform	SM 9223 B.	Absent	/100ml	1	03/12/14
	Oak Way		<i>E-coli</i>	IDEXX	Absent	/100ml	1	03/12/14

Report Completion date: 3/12/14

Reviewed: 

Amanda Smith, Lab Director

## Definitions

Absent: **Less than 1 CFU/100mLs**

Present: **1 or more CFU/100mLs**

CFU: **Colony Forming Unit**