Miller Drilling Co.
329 N. Main St.
Templeton, CA 93465
(805) 434-1888

Miller Drilling Co.

Contractors License No. 324634

PUMP TEST REPORT

Job# 19244

WELL OWNER: RICK SMITH
BILLING ADDRESS: 2844 ROUNSEVEL TERRACE
LAGUNA BEACH, CA
92651

Pump Set: 500' Well #: 5"
Pump Size: 1 1/2 HP Well Depth: 680'
Testing Method: EXISTING PUMP
Perf Rec: 400-440 460-480 560-580 600-680
APN:
LOCATION: 5095 WHITETAIL

Standing Level Before Test: 445.00

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:25	447	CLEAR, NO ODOR		8.7
8:30	447.8	CLEAR, NO ODOR		8.7
8:35	448	CLEAR, NO ODOR		8.7
8:45	448.2	CLEAR, NO ODOR		
12:05	449	CLEAR, NO ODOR		8.6
12:20	449	CLEAR, NO ODOR		8.6
12:25	449			8.6
	RECOVERY			
1 MIN	447			
5 MIN	446.4			
10 MIN	445.9			

Notes: STOP: 458040 8.67 GPM AVG
START: 455960

STANDING LEVEL AFTER TEST: 445.9 AFTER 10 MIN
FINAL TEST RESULTS: Produced: 8.6 GPM for 4 hours on: 6/17/2014
Test Run By: JAC